

LEED COMPLIANCE SUMMARY**(Part 2 of 4) EAP-2**

Project Name

Nonresidential Sample Building

Date

*10/25/2016***ENERGY TYPE SUMMARY**

| Energy Type | Utility Rate Description | Baseline Virtual Rate (\$ per unit energy) | Proposed Virtual Rate (\$ per unit energy) | Units of Energy | Units of Demand |
|-------------|--------------------------|---|---|-----------------|-----------------|
| Electricity | PG&E A-6 | 0.26 | 0.26 | kWh | kW |
| Natural Gas | PG&E G-NR1 | 1.09 | 1.09 | therms | MBH |
| | | | | | |
| | | | | | |

RENEWABLE ENERGY SOURCE SUMMARY

| Renewable Source | Backup Energy Type | Annual Energy Generated | Rated Capacity | Renewable Energy Cost |
|------------------|--------------------|-------------------------|----------------|-----------------------|
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |

EXCEPTIONAL CALCULATION MEASURE SHORT DESCRIPTION

| Energy Type(s) | Annual Energy Savings by Energy Type | Annual Cost Savings | Exceptional Calculation Measure Narrative: |
|----------------|--------------------------------------|---------------------|--|
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |

LEED COMPLIANCE SUMMARY

(Part 3 of 4) EAP-2

| | |
|---|---------------------------|
| Project Name <i>Nonresidential Sample Building</i> | Date <i>10/25/2016</i> |
|---|---------------------------|

BASELINE PERFORMANCE – PERFORMANCE RATING METHOD COMPLIANCE

| End Use | Process? | Baseline Design Energy Type | Units of Annual Energy & Peak Demand | Baseline (0 deg rotation) | Baseline (90 deg rotation) | Baseline (180 deg rotation) | Baseline (270 deg rotation) |
|----------------------------------|-------------------------------------|-----------------------------|--------------------------------------|---------------------------|----------------------------|-----------------------------|-----------------------------|
| <i>Interior Lighting</i> | <input type="checkbox"/> | <i>Electricity</i> | <i>kWh</i> | <i>16484</i> | <i>16484</i> | <i>16484</i> | <i>16484</i> |
| | | | <i>kW</i> | <i>4.0</i> | <i>4.0</i> | <i>4.0</i> | <i>4.0</i> |
| <i>Exterior Lighting</i> | <input type="checkbox"/> | <i>Electricity</i> | <i>kWh</i> | <i>7646</i> | <i>7646</i> | <i>7646</i> | <i>7646</i> |
| | | | <i>kW</i> | <i>1.9</i> | <i>1.9</i> | <i>1.9</i> | <i>1.9</i> |
| <i>Space Heating</i> | <input type="checkbox"/> | <i>NaturalGas</i> | <i>therms</i> | <i>32</i> | <i>26</i> | <i>32</i> | <i>37</i> |
| | | | <i>kBtu/hr</i> | <i>89.3</i> | <i>85.8</i> | <i>86.0</i> | <i>90.7</i> |
| <i>Space Cooling</i> | <input type="checkbox"/> | <i>Electricity</i> | <i>kWh</i> | <i>12900</i> | <i>13354</i> | <i>12871</i> | <i>12861</i> |
| | | | <i>kW</i> | <i>17.4</i> | <i>17.9</i> | <i>17.4</i> | <i>17.6</i> |
| <i>Fans-Interior</i> | <input type="checkbox"/> | <i>Electricity</i> | <i>kWh</i> | <i>30845</i> | <i>32603</i> | <i>31443</i> | <i>31130</i> |
| | | | <i>kW</i> | <i>6.0</i> | <i>6.3</i> | <i>6.1</i> | <i>6.1</i> |
| <i>Service Hot Water</i> | <input type="checkbox"/> | <i>NaturalGas</i> | <i>therms</i> | <i>882</i> | <i>882</i> | <i>882</i> | <i>882</i> |
| | | | <i>kBtu/hr</i> | <i>17.3</i> | <i>17.3</i> | <i>17.3</i> | <i>17.3</i> |
| <i>Receptacle Equipment</i> | <input checked="" type="checkbox"/> | <i>Electricity</i> | <i>kWh</i> | <i>16511</i> | <i>16511</i> | <i>16511</i> | <i>16511</i> |
| | | | <i>kW</i> | <i>4.5</i> | <i>4.5</i> | <i>4.5</i> | <i>4.5</i> |
| <i>Interior Lighting-Process</i> | <input checked="" type="checkbox"/> | <i>Electricity</i> | <i>kWh</i> | <i>9128</i> | <i>9128</i> | <i>9128</i> | <i>9128</i> |
| | | | <i>kW</i> | <i>1.6</i> | <i>1.6</i> | <i>1.6</i> | <i>1.6</i> |
| <i>Process Energy</i> | <input checked="" type="checkbox"/> | <i>Electricity</i> | <i>kWh</i> | <i>15003</i> | <i>15003</i> | <i>15003</i> | <i>15003</i> |
| | | | <i>kW</i> | <i>3.6</i> | <i>3.6</i> | <i>3.6</i> | <i>3.6</i> |
| <i>Exterior</i> | <input checked="" type="checkbox"/> | <i>NaturalGas</i> | <i>therms</i> | <i>323</i> | <i>323</i> | <i>323</i> | <i>323</i> |
| | | | <i>kBtu/hr</i> | <i>5.4</i> | <i>5.4</i> | <i>5.4</i> | <i>5.4</i> |
| <i>Exterior</i> | <input checked="" type="checkbox"/> | <i>Electricity</i> | <i>kWh</i> | <i>1078</i> | <i>1078</i> | <i>1078</i> | <i>1078</i> |
| | | | <i>kW</i> | <i>0.2</i> | <i>0.2</i> | <i>0.2</i> | <i>0.2</i> |
| | <input type="checkbox"/> | | | | | | |
| | <input type="checkbox"/> | | | | | | |

BASELINE ENERGY COSTS

| Energy Type | Baseline Cost (0 deg rotation) | Baseline Cost (90 deg rotation) | Baseline Cost (180 deg rotation) | Baseline Cost (270 deg rotation) | Baseline Building Performance |
|-----------------------|--------------------------------|---------------------------------|----------------------------------|----------------------------------|-------------------------------|
| <i>Electricity</i> | <i>28527</i> | <i>29150</i> | <i>28684</i> | <i>28609</i> | <i>28743</i> |
| <i>NaturalGas</i> | <i>1343</i> | <i>1336</i> | <i>1343</i> | <i>1348</i> | <i>1343</i> |
| Total Baseline Costs: | <i>29870</i> | <i>30486</i> | <i>30027</i> | <i>29957</i> | <i>30085</i> |

LEED COMPLIANCE SUMMARY (Part 4 of 4) EAP-2

| | |
|---|---------------------------|
| Project Name <i>Nonresidential Sample Building</i> | Date <i>10/25/2016</i> |
|---|---------------------------|

PERFORMANCE RATING TABLE – PERFORMANCE RATING METHOD COMPLIANCE

| End Use | Process? | Proposed Design Energy Type | Baseline Building Results | Proposed Design Units | Proposed Building Results | Percentage Savings |
|----------------------------------|-------------------------------------|-----------------------------|---------------------------|-----------------------|---------------------------|--------------------|
| <i>Interior Lighting</i> | <input type="checkbox"/> | <i>Electricity</i> | 16484 | kWh | 15185 | 7.9 % |
| | | | 4.0 | kW | 3.4 | 16.1 % |
| <i>Exterior Lighting</i> | <input type="checkbox"/> | <i>Electricity</i> | 7646 | kWh | 4509 | 41.0 % |
| | | | 1.9 | kW | 1.1 | 41.0 % |
| <i>Space Heating</i> | <input type="checkbox"/> | <i>NaturalGas</i> | 32 | therms | 48 | -50.2 % |
| | | | 87.9 | kBtu/hr | 104.3 | -18.6 % |
| <i>Space Cooling</i> | <input type="checkbox"/> | <i>Electricity</i> | 12996 | kWh | 12479 | 4.0 % |
| | | | 17.6 | kW | 15.9 | 9.4 % |
| <i>Fans-Interior</i> | <input type="checkbox"/> | <i>Electricity</i> | 31505 | kWh | 25226 | 19.9 % |
| | | | 6.1 | kW | 4.7 | 22.8 % |
| <i>Service Hot Water</i> | <input type="checkbox"/> | <i>NaturalGas</i> | 882 | therms | 922 | -4.5 % |
| | | | 17.3 | kBtu/hr | 17.9 | -3.7 % |
| <i>Receptacle Equipment</i> | <input checked="" type="checkbox"/> | <i>Electricity</i> | 16511 | kWh | 16511 | 0.0 % |
| | | | 4.5 | kW | 4.5 | 0.0 % |
| <i>Interior Lighting-Process</i> | <input checked="" type="checkbox"/> | <i>Electricity</i> | 9128 | kWh | 9128 | 0.0 % |
| | | | 1.6 | kW | 1.6 | 0.0 % |
| <i>Process Energy</i> | <input checked="" type="checkbox"/> | <i>Electricity</i> | 15003 | kWh | 15003 | 0.0 % |
| | | | 3.6 | kW | 3.6 | 0.0 % |
| <i>Exterior</i> | <input checked="" type="checkbox"/> | <i>NaturalGas</i> | 323 | therms | 323 | 0.0 % |
| | | | 5.4 | kBtu/hr | 5.4 | 0.0 % |
| <i>Exterior</i> | <input checked="" type="checkbox"/> | <i>Electricity</i> | 1078 | kWh | 1078 | 0.0 % |
| | | | 0.2 | kW | | 0.0 % |
| | <input type="checkbox"/> | | | | | |
| | <input type="checkbox"/> | | | | | |

ENERGY COST AND CONSUMPTION BY ENERGY TYPE

| | Baseline Design | | | Proposed Design | | | Percent Savings | |
|------------------------------|-----------------|-------------|----------|-----------------|-------------|----------|-----------------|--------|
| Energy Type | Energy Use | | Cost | Energy Use | | Cost | Energy Use | Cost |
| <i>Electricity</i> | 110,351 | kWh | 28,743 | 99,120 | kWh | 25,900 | 10.2 % | 9.9 % |
| <i>NaturalGas</i> | 1,237 | therms | 1,343 | 1,293 | therms | 1,403 | -4.5 % | -4.5 % |
| Subtotal (Model Outputs): | 500,332 | (kBtu/year) | \$30,085 | 467,585 | (kBtu/year) | \$27,303 | 6.5 % | 9.2 % |

Table 1.4.1 - Opaque Building Envelope

Instructions: Complete the Opaque Building Envelope Requirements section, then describe each unique opaque building envelope construction on a separate row in the Opaque Building Envelope Constructions table (required inputs are green). Note that extra rows can be added using the button to the lower left of each construction type as necessary. An example of the expected level of detail has been provided for each type of construction. Please refer to the Helpful Notes for information about Appendix G modeling protocol. For any information not applicable to the project, simply enter "N/A". Baseline Case Information will autogenerate for New Construction Opaque Assemblies when the space conditioning category is selected.

Opaque Building Envelope Requirements

For projects modeled using ASHRAE 90.1-2007 Appendix G, select the climate zone: DOE Climate Zone 3B

| | | |
|--|---|---|
| Select the appropriate description for the project: | | <input checked="" type="checkbox"/> The project is 100% new Construction <input type="checkbox"/> The project is 100% existing renovation <input type="checkbox"/> The project is a Combination of new construction and existing renovation |
| | For existing spaces, have there been any changes to the space conditioning category (for example, previously unconditioned spaces becoming fully conditioned)? | <input checked="" type="checkbox"/> No Changes to space conditioning categories <input type="checkbox"/> Yes, and the associated constructions in the Baseline case have been modeled using the Appendix G requirements for new |
| Check the applicable space conditioning categories included in the project: | | <input checked="" type="checkbox"/> Nonresidential <input type="checkbox"/> Residential <input type="checkbox"/> Semiheated <input checked="" type="checkbox"/> Unconditioned |
| | All spaces qualifying as semiheated are not defined as heated per Table 3.1 or indirectly conditioned (see Section 3.2 definition of <i>space</i>) | <input type="checkbox"/> Yes <input checked="" type="checkbox"/> N/A (no semiheated spaces) |
| | Opaque envelope assemblies separating conditioned space from unconditioned or semiheated space are modeled using semiheated envelope assemblies per the ASHRAE 90.1-2007 User's Manual , Section 5.1.1, Envelope Component Assemblies (Page 5-2). | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> N/A (no opaque assemblies separating conditioned and semiheated / unconditioned space) |
| All Baseline new construction opaque envelope assemblies were modeled as required by Table 5.5 for the project's climate zone and Table G3.1#5(b) as delayed assemblies. See the Helpful Notes for each opaque assembly for more information. | | Yes |
| All Proposed roofs, above-grade exterior walls, below-grade exterior walls, exposed floors, slab-on-grade floors, and opaque doors were modeled as-designed and with assembly U-factors / C-factors / F-factors consistent with Appendix A values | | Yes |
| Infiltration rates and schedules have been modeled identically in the Baseline and Proposed case | | Yes |
| For each item entered as "No" above, describe the applicable ASHRAE 90.1 Appendix G exception(s) that apply, or the circumstances preventing the opaque envelope parameters from being modeled as required. If the energy simulation software is not capable of modeling the required parameters, describe the adjustments that were made to provide a thermodynamically similar representation or provide a narrative justifying why the predicted energy performance results will not be influenced: | | |
| | | |

Opaque Building Envelope Constructions

| Model Input Parameter | New / Existing | Space-Conditioning Category | Baseline Case | | Proposed Case | | Baseline Roof Reflectivity Modeled as 0.3? | Proposed Roof Reflectivity Modeled |
|---|----------------|-----------------------------|--|---------------------------------------|--|---------------------------------------|--|------------------------------------|
| | | | Description | Assembly U-factor/ C-factor/ F factor | Description | Assembly U-factor/ C-factor/ F factor | | |
| Roof Constructions | Helpful Notes: | | •New roofs: insulation entirely above deck with U-factor from appropriate Table 5.5 per Table G3.1#5(b). •Existing roofs: existing conditions per Table G3.1#5(f). | | Proposed construction assembly U-factor should be as-designed and consistent with Appendix A of ASHRAE 90.1 (list Appendix A Table referenced) | | 0.3 per Table G3.1#5(e) | 0.3 or 0.45 per Table G3.1#5(c) |
| | New | Cond | New | 0.039 | R-30 Roof Attic | 0.038 | 0.30 | 0.10 |
| | | | | | | | | |
| Above-Grade Exterior Wall Constructions | Helpful Notes: | | •New above-grade walls: steel-framed with U-factor from appropriate Table 5.5 per Table G3.1#5(b). •Existing above-grade walls: existing conditions per Table G3.1#5(f). | | Proposed construction assembly U-factor should be as-designed and consistent with Appendix A of ASHRAE 90.1 (list Appendix A Table referenced) | | | |
| | New | Cond | New | 0.077 | R-13 Wall | 0.102 | | |
| | | | | | | | | |
| Below-Grade Exterior Wall Constructions | Helpful Notes: | | •New below-grade walls: 8" medium weight concrete block with solid grouted cores as defined in A4.1 with C-factor from appropriate Table 5.5 per Table G3.1#5(b). •Existing below-grade walls: existing conditions per Table G3.1#5(f). | | Proposed construction assembly C-factor should be as-designed and consistent with Appendix A of ASHRAE 90.1 (list Appendix A Table referenced) | | | |
| | | | | | | | | |
| | | | | | | | | |
| Exposed Floor Constructions | Helpful Notes: | | •New floors: steel-joint with U-factor from appropriate Table 5.5 per Table G3.1#5(b). •Existing floors: existing conditions per Table G3.1#5(f). •For floor assemblies above unconditioned or semiheated space, select the space conditioning category as semiheated per 90.1-2007 User's Manual, Section 5.1.1-Envelope Component Types (Figure 5-C) | | Proposed construction assembly U-factor should be as-designed and consistent with Appendix A of ASHRAE 90.1 (list Appendix A Table referenced) | | | |
| | | | | | | | | |
| | | | | | | | | |
| Slab-On-Grade Floors | Helpful Notes: | | •New slab-on-grade floors: unheated 6" concrete slab with F-factor from appropriate Table 5.5 per Table G3.1#5(b). •Existing slab-on-grade floors: existing conditions per Table G3.1#5(f). | | Proposed construction assembly F-factor should be as-designed and consistent with Appendix A of ASHRAE 90.1 (list Appendix A Table referenced) | | | |
| | New | Cond | New | 0.730 | Slab On Grade | 0.654 | | |
| | | | | | | | | |
| Opaque Doors | Helpful Notes: | | •New opaque doors: U-factor from appropriate Table 5.5 per Table G3.1#5(b). •Existing opaque doors: existing conditions per Table G3.1#5(f). | | Proposed construction assembly U-factor should be as-designed and consistent with A7.1 of ASHRAE 90.1 for unlabeled doors | | | |
| | New | Cond | New | 0.700 | Wood Door | 0.500 | | |
| | | | | | | | | |

Additional notes:

Table 1.4.2A - Shading & Orientation

Instructions: Provide the following shading and orientation information (required inputs are green). An example of the expected level of detail has been provided for each input. Please refer to the Helpful Notes for information about Appendix G modeling protocol. For any information not applicable to the project, simply enter "N/A".

| Model Input Parameter | | Baseline Case | | | Proposed Case | | |
|---|-------------|---|-----------------------|------|---|-----------------------|------|
| Helpful Notes: | | <ul style="list-style-type: none">•All vertical glazing flush with exterior wall and no shading projections per Table G3.1#5(c)•No manual shading devices such as blinds or shades per Table G3.1#5(c)•No self-shading per Table G3.1#5•Total vertical fenestration areas for new construction equal to Proposed up to 40% maximum, and distributed on each face of the building in the same proportions as the Proposed design per Table G3.1#5(c)•Total skylight area for new construction equal to Proposed up to 5% maximum per Table G3.1#5(d) | | | <ul style="list-style-type: none">•No manual shading devices such as blinds or shades per Table G3.1#5(d)•Permanent shading devices (such as fins, overhangs, and light shelves) and automatically controlled shades or blinds may be modeled per Table G3.1#5(d)•Shading by adjacent structures and terrain may be modeled, but must be modeled identically in the Baseline case | | |
| Shading Devices | | <div><input checked="" type="checkbox"/> No shading projections, manual shading devices, or self-shading have been modeled for the Baseline building</div> <div><input type="checkbox"/> Any shading by adjacent structures and terrain has been modeled identically to the Proposed case (if applicable)</div> | | | Modeled with Overhangs, | | |
| Building Shape & Orientation | | <div><input checked="" type="checkbox"/> The Baseline building is modeled with the same shape and orientation as the Proposed building, and for new construction rotated 90°, 180°, and 270°</div> | | | | | |
| Above-Grade Wall & Vertical Glazing Area by Orientation | Orientation | Above Grade Wall Area (ft ²) | Vertical Glazing Area | | Above Grade Wall Area (ft ²) | Vertical Glazing Area | |
| | | | (ft ²) | (%) | | (ft ²) | (%) |
| | North | 800 | 320 | 40 % | 800 | 320 | 40 % |
| | East | 1,040 | 320 | 31 % | 1,040 | 320 | 31 % |
| | South | 2,000 | 260 | 13 % | 2,000 | 260 | 13 % |
| | West | 720 | 0 | 0 % | 720 | 0 | 0 % |
| | Total | 4,560 | 900 | 20 % | 4,560 | 900 | 20 % |
| Roof & Skylight Area | | Roof Area (ft ²) | Skylight Area | | Roof Area (ft ²) | Skylight Area | |
| | | | (ft ²) | (%) | | (ft ²) | (%) |
| | | 2,880 | 0 | 0 % | 2,880 | 0 | 0 % |

Table 1.4.2B - Fenestration

Instructions: Describe each unique fenestration assembly on a separate row in the following table (required inputs are green). Note that additional rows can be expanded using the Add a Line button to the lower left of each fenestration type as necessary. An example of the expected level of detail has been provided for each type of fenestration. Please refer to the Helpful Notes for information about Appendix G modeling protocol. For any information not applicable to the project, simply enter "N/A". Baseline Case Information will autogenerate for New Construction Nonresidential or Residential Vertical Glazing and for New Construction Nonresidential skylights when the Baseline Description is selected from one of the items listed.

| Model Input Parameter | New / Existing | Space Conditioning Category | Baseline Case | | | Proposed Case | | | |
|-----------------------|----------------|-----------------------------|--|-------------------|------|---|-------------------|------|------|
| | | | Description | Assembly U-factor | SHGC | Description | Assembly U-factor | SHGC | VLT |
| Vertical Glazing | Helpful Notes: | | <ul style="list-style-type: none">•New vertical glazing: assembly U-factor and SHGC from appropriate Table 5.5 per Table G3.1#5(c).•Existing vertical glazing: existing conditions per Table G3.1#5(f). | | | Proposed vertical glazing assembly U-factor should be as-designed and account for the impact of the frames on the whole assembly. Reference Table A8.2 of ASHRAE 90.1 as necessary. | | | |
| | New | Cond | Standard | 0.60 | 0.25 | Double Metal Tinted | 0.71 | 0.60 | 0.72 |
| | | | | | | | | | |
| Skylights | Helpful Notes: | | <ul style="list-style-type: none">•New skylights: assembly U-factor and SHGC from appropriate Table 5.5 per Table G3.1#5(d).•Existing skylights: existing conditions per Table G3.1#5(f). | | | Proposed skylight assembly U-factor should be as-designed and account for the impact of the frames on the whole assembly. Reference Tables A8.1A and A8.1B of ASHRAE 90.1 as necessary. | | | |
| | | | | | | | | | |
| | | | | | | | | | |

How were the Proposed case framed assembly fenestration U-factors determined?

Additional notes:

Table 1.4.3A - Interior Lighting

Instructions: Confirm that the energy model complies with the Interior lighting requirements listed, and provide a narrative explaining any discrepancies. Select the interior lighting categorization procedure, and then complete the corresponding lighting table (required inputs are green). An example of the expected level of detail has been provided for each input. Please refer to the Helpful Notes for information about Appendix G modeling protocol. For any information not applicable to the project, simply enter "N/A". For projects using California Title-24, the following Title-24 lighting compliance forms may be uploaded in lieu of this sheet (2008 - LTG-1C, LTG-2C, LTG-3C, LTG-5-C, OLTG-1C, OLTG-2C, SLTG-1C; 2005 - LTG-1C, LTG-2-C, LTG-3-C, LTG-4-C, LTG-5-C, LTG-9-C, OLTG-1-C, OLTG-2-C, OLTG-3-C, OLTG-4-C).

Interior Lighting Requirements

| | |
|--|--|
| All lighting schedules have been modeled identically in the Baseline and Proposed case and reflect the anticipated operating schedules of each space | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No |
| The Proposed lighting power includes all lighting system components shown or provided for on the plans (including lamps and ballasts and task and furniture-mounted fixtures except where specifically exempted) | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No |
| Per ASHRAE 90.1-2007, Section 9.1.4 (c), and (d): For all line-voltage lighting track and plug-in busway , designed to allow the addition and/or relocation of luminaires without altering the wiring of the system, the proposed case wattage is modeled as: (a) the specified wattage of the luminaires included in the sytem with a minimum of 30 W/lin ft, OR (b) the wattage limit of the system's circuit breaker, OR (c) the wattage limit of other permanent current-limiting device(s) For all low-voltage lighting track, cable conductor, rail conductor , and other flexible lighting systems that allow the addition and/or relocation of luminaires without altering the wiring of the system, the proposed case wattage is modeled as the wattage of the transformer supplying the | <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A |

For each item entered as "No" above, describe the applicable ASHRAE 90.1 Appendix G exception(s) that apply, or the circumstances preventing the lighting parameters from being modeled as required. If the energy simulation software is not capable of modeling the required parameters, describe the adjustments that were made to provide a similar representation or provide a narrative justifying why the predicted energy performance results will not be influenced:

Categorization Procedure

| | |
|---|--|
| Select the categorization procedure (Building Area or Space by Space Method) used to determine the lighting power density (LPD) in the Proposed and Baseline case | <input type="checkbox"/> Building Area Method <input checked="" type="checkbox"/> Space by Space Method |
|---|--|

Space by Space Method

| Table 9.6.1 Space Type | Total Area of Space Type (ft ²) | Baseline Case | Proposed Case | | | | |
|--|---|--|---|---|-----------------------------|----------------------------------|----------------------|
| | | Modeled LPD (Excluding Section 9.6.2 Additional Lighting) (W/ft ²) | Design LPD (Excluding Section 9.6.2 Additional Lighting) (W/ft ²) | Automatic Lighting Controls and Space Types | Table G3.2 Power Adjustment | Modeled LPD (W/ft ²) | Daylighting Controls |
| Helpful Notes: Refer to 90.1 User's Manual for definitions of Active vs. Inactive Storage, General Low Bay vs. General High Bay Manufacturing, and Fine vs. Medium/Bulky Material Storage Warehouse | | Modeled using the maximum allowance from Table 9.6.1 <i>(values provided for reference - overwrite if modeled differently)</i> | •Lighting power should be modeled as designed (or installed) including all lighting system components (lamps and ballasts) •Credit for automatic lighting controls should be modeled using the appropriate power adjustment from Table G3.2, applied only to the controlled lighting power and not where required by 9.4.1.2 per Table G3.1#6(g) [conference rooms; meeting rooms; employee lunch and break rooms; classrooms excepting Pre-K through 12th grade, laboratory, or shop] •Automatic daylighting controls must either be modeled directly in the simulation, or modeled using schedule adjustments determined by a separate daylighting analysis per Table G3.1#6(f) | | | | |
| Retail Sales Area | 1,280 | 1.680 | 0.969 | | 0.000 | 0.969 | |
| Storage | 800 | 0.630 | 0.388 | | 0.116 | 0.271 | |
| Office Open Plan | 1,920 | 0.980 | 0.872 | | 0.174 | 0.698 | |
| Dining Area | 1,280 | 0.650 | 1.234 | | 0.000 | 1.234 | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| Total | 5,280 | 1.017 | 0.910 | | | 0.829 | |

Interior Process Lighting (if applicable)

| Description | Section 9.2.2.3 Exemption | Total Process Lighting Power (Watts) | Modeled Identically In Baseline? |
|------------------|--|--------------------------------------|---|
| Helpful Notes: | Any lighting not regulated by ASHRAE 90.1 is considered process and must be modeled identically in the Proposed and Baseline case unless an Exceptional Calculation is submitted | | |
| Process Lighting | | 1,920 | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No |

Table 1.4.3B - Exterior Lighting

Instructions: Select the applicable exterior lighting categories and then complete the corresponding lighting table(s) (required inputs are green). An example of the expected level of detail has been provided for each input. Please refer to the Helpful Notes for information about Appendix G modeling protocol. For any information not applicable to the project, simply enter "N/A".

Exterior Lighting Requirements

| | |
|--|--|
| The exterior lighting power values reported below are consistent with the SSc8 (Light Pollution Reduction Form) | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> N/A (SSc8 not submitted) |
| Additional lighting power allowance has not been claimed in the Baseline case for surfaces that are not provided with lighting in the actual design and lighting fixtures have not been double-counted for different exterior surfaces | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No |

Exterior Lighting Categories

| | |
|---|--|
| Check all applicable exterior lighting categories (Tradable and/or Nontradable) included in the project (program takes a few seconds to generate input table) | <input checked="" type="checkbox"/> The Project includes Tradable Exterior Lighting <input type="checkbox"/> The Project includes Nontradable Exterior Lighting |
|---|--|

Tradable Surfaces

| Table 9.4.5 Tradable Exterior Lighting Application | Required Input (Area or Length) | Total Area (ft ²) or Length (ft) | Baseline Case | | Proposed Case |
|---|---------------------------------|--|--|----------------------------------|---|
| | | | Allowed LPD | Lighting Power Allowance (Watts) | Design Lighting Power (Watts) |
| Helpful Notes: •Only enter area or length of illuminated surface in the design •Fixtures cannot be double-counted for multiple exterior surface types | | | Allowance calculated using the maximum lighting power density from Table 9.4.5 | | Lighting power should be modeled as designed (or installed) |
| Automotive Hardscape | Area | 12,000 | 0.100 | 1,200 | 1,150 |
| | | | | | |
| | | | | | |
| Subtotal: Tradable surface lighting allowance | | | | 1,200 | 1,150 |
| Total Tradable surface lighting allowance including 5% unrestricted allowance | | | | 1,260 | |

Nontradable Surfaces

| Table 9.4.5 Nontradable Exterior Lighting Application | Required Input | Quantity of Required Input for Project | Baseline Case | | Proposed Case |
|---|----------------|--|---|----------------------------------|---|
| | | | Allowed LPD | Lighting Power Allowance (Watts) | Design Lighting Power (Watts) |
| Helpful Notes: •Only enter area or length of illuminated surface in the design •Fixtures cannot be double-counted for multiple exterior surface types | | | Total allowance calculated using the lesser of the design lighting power, or the lighting power allowance used, since no credit is permitted for nontradable surfaces | | Lighting power should be modeled as designed (or installed) |
| Building facades | area | 0 | 0 | 0 | |
| Building facades | length | 0 | 4 | 0 | |
| ATMs and night depositories | Number of ATMs | 0 | 270 + 90 | 0 | |
| Entrances and gatehouse inspection stations at guarded facilities | Uncovered Area | 0 | 1 | 0 | |
| Loading areas for law enforcement, fire, ambulance, and other emergency service vehicles | Uncovered Area | 0 | 1 | 0 | |
| Drive-through windows at fast food restaurants | Drive-throughs | 0 | 400 | 0 | |
| Parking near 24-hour retail entrances | Main Entries | 0 | 800 | 0 | |
| Subtotal: Nontradable surface lighting allowance | | | | 0 | |
| Total Nontradable surface lighting allowance including 5% unrestricted allowance | | | | 0 | |

| Input Parameter | Baseline Case | Proposed Case |
|--|---------------|---------------|
| Total Exterior Lighting Power Calculated Above (Watts) | 1,950 | 1,150 |
| Total Exterior Lighting Power Modeled (Watts) | 1,950 | |

Additional notes:

| |
|--|
| |
|--|

Instructions: Select the method used to model receptacle equipment, and then complete the corresponding receptacle equipment table (required inputs are green). Other process equipment should be reported in the bottom table. An example of the expected level of detail has been provided for each input. Please refer to the Helpful Notes for information about Appendix G modeling protocol. For any information not applicable to the project, simply enter "N/A".

| | |
|--|---|
| All receptacle equipment and other process equipment designed or anticipated for the building have been accounted for in the energy models. | <input type="checkbox"/> Yes <input type="checkbox"/> No |
| If process energy accounts for less than 25% of the total Baseline energy cost, an additional narrative justification for the low process cost has been provided in the supporting documentation. Note: process energy should not be arbitrarily set to 25% of the total Baseline cost, but should reflect the actual process loads anticipated for the building. | <input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A (>25%) |

Indicate whether the receptacle equipment was modeled using an average equipment power density for the building, equipment power densities by space type, or by entering the power associated with specific devices in each space (may select more than one)

- ☐ Building Average Equipment Power Density (W/sq.ft.)
- ☒ Space by Space Equipment Power Density (W/sq.ft.)
- ☐ Equipment Power by Device (Watts)

| Space Type | Total Area of Space Type | Equipment Power Density (W/ft ²) | Equipment Included in Power Density | Baseline Modeled Identically? |
|----------------|--|--|--|-------------------------------|
| Helpful Notes: | •All receptacle loads must be modeled identically between the Proposed and Baseline case and included in the simulations per Table G3.1#12 •Any credit for improved receptacle equipment must be submitted using the Exceptional Calculation Method | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| Total | | | Total Power Modeled Using Space-by-Space Method (kW): | |

| Equipment Type (Change/Add Labels as Necessary) | Energy Source | Energy Demand (kW) | Modeling Parameters | Baseline Modeled Identically? |
|--|---|--------------------------|---|-------------------------------------|
| Helpful Notes: | •All process loads must be modeled identically between the Proposed and Baseline case and included in the simulations per Table G3.1#12 •Any credit for improved process equipment must be submitted using the Exceptional Calculation Method •Exception: When the process or receptacle equipment includes components regulated by minimum efficiency requirements in ASHRAE 90.1, these components may be modeled in the Baseline Case using the minimum ASHRAE 90.1 efficiencies, and in the proposed case using actual proposed case efficiencies (e.g. Baseline may be modeled using furnace efficiencies from Table 6.8.1E, boiler efficiencies from Table 6.8.1G, chiller efficiencies from Table 6.8.1C or Section 6.4.1.2, or motor efficiency from Section 10.4). | | | |
| Elevators/Escalators | | | | |
| Refrigeration Equipment | | | | |
| Kitchen Equipment | | | | |
| Data Center Equipment | | | | |
| Process Loads | | | | |
| Total | | | Total Power for Other Process Equipment (kW): | |
| | | | Total Power for Building Process/Receptacle Equipment(kW): | |

Table 1.4.5 - Service Water Heating

Instructions: Complete the Service Water Heaters table for each unique type of system in the project (required inputs are green). Use the Add a System Type button for more than one type of system. Complete the Service Hot Water Fixtures table if credit is modeled for low-flow fixtures in the Proposed case. If the project includes service hot water circulation pumps, complete the Service Hot Water Pumps table. An example of the expected level of detail has been provided for each input. Please refer to the Helpful Notes for information about Appendix G modeling protocol. For any information not applicable to the project, simply enter "N/A".

Service Water Heaters

| Model Input Parameter | Baseline Case | Proposed Case |
|------------------------------|--|---|
| Helpful Notes: | <ul style="list-style-type: none">•New systems: minimum performance requirements from Table 7.8 per Table G3.1#11(b)•Existing systems: actual system inputs per Table G3.1#11(a)•Model separate service water heating system when design uses combined system with space heating per Table G3.1#11(e)•Condenser heat recovery as required by 6.5.6.2 per Table G3.1#11(f) | <ul style="list-style-type: none">•Service water heaters modeled as designed (or installed) per Table G3.1#11(a&b)•Where no service hot water system exists or has been specified but the building will have service hot water loads, a service hot water system should be modeled identical to the Baseline per Table G3.1#11(c)•For buildings with no service hot water loads, no service hot water system should be modeled per Table G3.1#11(d) |
| System Type & Fuel | Gas Fired | Gas Fired |
| Input Rating (kW, MBH, etc.) | 80,000 Btu/hr | 80,000 Btu/hr |
| Efficiency (EF, SL, %, etc.) | 80.0 % Efficiency | 78.0 % Efficiency |
| Storage Volume (gal) | 80.0 gallons | 80.0 gallons |
| Storage Temperature (°F) | 140 F | 140 F |
| Peak Hot Water Demand (gpm) | 0.768 | 0.768 |
| Condenser heat recovery | None | None |

Service Hot Water Fixtures

Note: This table is only required to be completed if credit is modeled in the Proposed case for low-flow fixtures

| Fixture Type | Fixture Outlet Temp (°F) | % Hot Water | Baseline Case | | | Proposed Case | | |
|----------------|--|-------------|---|--|-------------------------------------|--|--|-------------------------------------|
| | | | Flow Rate (gpm or gpc) | WEp1 Annual Total Water Consumption (kgal) | Annual Hot Water Consumption (kgal) | Flow Rate (gpm or gpc) | WEp1 Annual Total Water Consumption (kgal) | Annual Hot Water Consumption (kgal) |
| Helpful Notes: | <ul style="list-style-type: none">•Refer to Table 3 in Chapter 50 of 2011 ASHRAE Handbook-HVAC Applications for fixture outlet temps used to determine % hot water•% Hot water should account for the DHW supply-to-fixture delta T, and for the percentage hot water versus cold water usage (e.g. residential lavatories would be expected to have cold water usage associated with brushing teeth) | | <ul style="list-style-type: none">•Fixtures included in the WEp1 calculations: values must be consistent with the WEp1 form•Additional fixtures not included in WEp1: use Proposed values or provide supporting documentation for Baseline assumption (example: Energy Star documentation of average hot water usage for residential dishwasher or clothes washer) | | | Values should be consistent with the design (or installed) fixtures and WEp1 (if applicable) | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| Total | | | | | | | | |
| | | | Annual Equivalent Full Load Hours of DHW Operation | | | Annual Equivalent Full Load Hours of DHW Operation | | |
| | | | Calculated Peak Hourly Flow (gal/hour) | | | Calculated Peak Hourly Flow (gal/hour) | | |

Service Hot Water Pumps

| Model Input Parameter | Baseline Case | Proposed Case |
|----------------------------------|---|--|
| Helpful Notes: | <ul style="list-style-type: none">•Service hot water pumps should be modeled identically between the Proposed and Baseline case•Any credit for improved service hot water pumps must be submitted using the Exceptional Calculation Method | Service hot water pumps modeled as designed (or installed) |
| Number of Pumps | | |
| Total Pump Power (kW) | | |
| Type of Pump (Constant/Variable) | | |
| Pump Control | | |

Additional notes:

| |
|--|
| |
|--|

Instructions: Complete the Special Circumstances section, the Proposed and Baseline HVAC System Type(s) tables, and the HVAC Modeling Requirements checklist below. An example of the expected level of detail has been provided for each input. Please refer to the Helpful Notes for information about Appendix G modeling protocol. For any information not applicable to the project, simply enter "N/A".

| | | | |
|--|---|---|--------------------------|
| Is the project building connected to a district or campus thermal energy system where thermal energy is produced for or distributed to multiple buildings? | | <input type="checkbox"/> | <input type="checkbox"/> |
| | The district energy system includes (check all that apply): | <input type="checkbox"/> District Cooling <input type="checkbox"/> District Heating <input type="checkbox"/> CHP | |
| | Select how the district energy system has been modeled: <i>Note: "DES v2" refers to the document "Treatment of District or Campus Thermal Energy in LEED V2 and LEED 2009 – Design & Construction" dated August 10, 2010, which can be accessed at http://www.usgbc.org/ShowFile.aspx?DocumentID=7671</i> | <input type="checkbox"/> ASHRAE 90.1-2007 Appendix G without Addenda <input type="checkbox"/> ASHRAE 90.1-2007 Appendix G Addenda ai <input type="checkbox"/> California Title-24 Baseline default efficiencies <input type="checkbox"/> DES v2 Option 1 (Building Stand-Alone) <input type="checkbox"/> DES v2 Option 2 (Aggregate Building/DES) | |
| | For DES v2 Option 2, identify the method for evaluating the district plant average efficiency. | <input type="checkbox"/> Modeling Method <input type="checkbox"/> Monitoring Method | |

| | | | |
|---|---|---|--|
| Please indicate all relevant equipment located on the project site: | <input type="checkbox"/> Chillers | <input type="checkbox"/> Cooling Towers / Fluid Coolers | <input type="checkbox"/> Boilers for Space Heating / Backup Heat |
| | <input type="checkbox"/> Ground Source / Geothermal Heat Pump | <input type="checkbox"/> Combined Heat & Power (CHP) | |

| | | Yes | No |
|---|---|--------------------------|--------------------------|
| Does the project building include tenant or other unfinished spaces whose systems (HVAC, lighting, etc.) are not included in the project's scope of work? | | <input type="checkbox"/> | <input type="checkbox"/> |
| | <p>Select how the unfinished spaces have been modeled:</p> <p><input type="checkbox"/> All equipment in the unfinished spaces not included in the project scope of work has been modeled identically in the Baseline and Proposed case using the Baseline modeling requirements.</p> <p><input type="checkbox"/> Credit has been modeled in the Proposed case for energy efficiency measures that are specifically identified in signed tenant sales and lease agreements (LEED Core & Shell only. New Construction must be modeled</p> | | |

[illegible]

Baseline HVAC System Type(s)

| Model Input Parameter | Table G3.1.1A System Type (or Semiconditioned System Description) | G3.1.1 Exception (or Semiconditioned Capacity and Area) | Spaces Modeled |
|-----------------------|--|--|-----------------|
| Helpful Notes: | •Refer to Section G3.1.1 and Table G3.1.1A (including footnotes) for Primary HVAC System selection | | |
| Primary HVAC System | - Packaged DX | | Retail Zone |
| Primary HVAC System | - Packaged DX | | Office Zone |
| Primary HVAC System | - Packaged DX | | Restaurant Zone |
| Primary HVAC System | - | | |
| Primary HVAC System | - | | |
| Primary HVAC System | - | | |
| Primary HVAC System | - | | |
| Primary HVAC System | - | | |
| Primary HVAC System | - | | |
| Primary HVAC System | - | | |
| Primary HVAC System | - | | |
| Primary HVAC System | - | | |
| Primary HVAC System | - | | |
| Primary HVAC System | - | | |
| Primary HVAC System | - | | |
| Primary HVAC System | - | | |
| Primary HVAC System | - | | |
| Primary HVAC System | - | | |
| Primary HVAC System | - | | |
| Primary HVAC System | - | | |
| Primary HVAC System | - | | |
| Primary HVAC System | - | | |
| Primary HVAC System | - | | |
| Primary HVAC System | - | | |
| Primary HVAC System | - | | |
| Primary HVAC System | - | | |
| Primary HVAC System | - | | |
| Primary HVAC System | - | | |
| Primary HVAC System | - | | |
| Primary HVAC System | - | | |
| Primary HVAC System | - | | |
| Primary HVAC System | - | | |
| Other HVAC System(s) | - | | |
| | - | | |

HVAC Modeling Requirements

| | | |
|---|--|-----|
| Instructions: After completing the information above, click "Refresh Modeling Requirements" to the left. All Proposed and Baseline HVAC system types must be entered above to generate the correct modeling requirements below. After clicking "Refresh Modeling Requirements", identify each item as "Yes" or "No", and provide a further description for any items marked as "No". | | |
| Proposed HVAC Requirements | All Proposed HVAC systems and related parameters, such as equipment capacities, efficiencies, airflows, fans, etc. have been modeled as designed and are consistent with supporting documentation uploaded in LEED Online | Yes |
| | Each Proposed HVAC thermal zone has been modeled as a separate thermal block except as allowed by Table G3.1#7 | Yes |
| | All Proposed HVAC systems serving conditioned spaces have been modeled with heating and cooling as required by Table G3.1#1(b), with heating and/or cooling added as necessary identically to the Baseline case per Table G3.1#10(c&d) except where System types (9) or (10) have been modeled in accordance with Addendum dn | Yes |
| | All Proposed HVAC systems and related parameters can be modeled directly in the energy simulation program used | Yes |
| | All Proposed fan part-load efficiency curves for variable volume fans have been modeled identically to the Baseline curves for variable volume fans (if not, provide a description of the fan curves used in the space at the bottom of this table, and confirm that the proposed case curves are representative of the actual building design) | Yes |

For each item entered as "No" above, describe the applicable ASHRAE 90.1 Appendix G exception(s)

| | | | | | |
|--|--|--|--|--|--|
| | | | | | |
|--|--|--|--|--|--|

Table 1.4.7A - Baseline Air-Side HVAC System Schedule

Instructions: Enter all applicable input parameters for the Baseline air-side HVAC systems below. All systems included in the model should be entered. Each individual system may be entered separately, or multiple systems may be grouped together if all input parameters identified with an (*) are similar. The table is set up for two unique HVAC systems (or two groups of similar systems), and additional systems (or groups of similar systems) should be added as necessary using the Add a System button. An example of the expected level of detail has been provided for each input. Please refer to the Helpful Notes for information about Appendix G modeling protocol. For any information not applicable to the project,

Note: All Baseline systems must be identified in the General HVAC Tab in order to display the relevant Baseline

Table 1.4.7A - Baseline Air-Side HVAC System Schedule

| Model Input Parameter | Helpful Notes | HVAC System / Group | | HVAC System / Group | | HVAC System / Group | | Totals |
|---|--|-------------------------------|--------|-------------------------------|--------|-------------------------------|--------|--------|
| | | Description | Units | Description | Units | Description | Units | |
| *System Type | | Packaged DX | | Packaged DX | | Packaged DX | | |
| System Designation(s) | Consistent with designations used in model | Standard System-0 | | Standard System-1 | | Standard System-2 | | |
| Number of Similar Systems | | 1 | | 1 | | 1 | | |
| Total Cooling Capacity | Auto-sized with 15% oversizing per G3.1.2.2 | 83 | kBtu/h | 109 | kBtu/h | 146 | kBtu/h | 338 |
| *Table 6.8.1 Unitary Cooling Capacity Range | •Systems 1 & 2: Table 6.8.1D •Systems 3, 5, & 6: Table 6.8.1A •System 4: Table 6.8.1B •Systems 7-10: N/A | | kBtu/h | | kBtu/h | | kBtu/h | |
| *Unitary Cooling Efficiency (EER or SEER) | Units should be consistent with the ASHRAE 90.1 minimum efficiency rating requirements for this system type | 11.0 EER | | 11.0 EER | | 10.8 EER | | |
| *Unitary Cooling Part-load Efficiency (if applicable) | Enter N/A if not applicable | n/a | | n/a | | n/a | | |
| Total Heating Capacity | Auto-sized with 25% oversizing per G3.1.2.2 | 33 | kBtu/h | 39 | kBtu/h | 61 | kBtu/h | 132 |
| *Table 6.8.1 Unitary Heating Capacity Range | •System 2: Table 6.8.1D •Systems 3 & 9: Table 6.8.1E •System 4: Table 6.8.1B •Systems 1, 5-8, 10: N/A | | kBtu/h | | kBtu/h | | kBtu/h | |
| *Unitary Heating Efficiency | List all relevant efficiencies (e.g. 3.2 COP at 47°F db/43°F wb, 2.0 COP at 17°F db/15°F wb outdoor air) | 78% AFUE | | 78% AFUE | | 78% AFUE | | |
| *Fan Control | •Systems 1-4, 9 & 10: Constant Volume •Systems 5-8: Variable Volume | Constant Volume | | Constant Volume | | Constant Volume | | |
| Supply Airflow | •Systems 1-8: Auto-sized based on 20°F ΔT •Systems 9-10: Auto-sized based on 105°F SAT | 1,885 | cfm | 2,677 | cfm | 3,073 | cfm | 7,634 |
| Outdoor Airflow | •If DCV modeled in Proposed only: ASHRAE 62.1 minimum ventilation rates reported in IEQp1 •All other cases: identical to Proposed | 320 | cfm | 288 | cfm | 750 | cfm | 1,358 |
| Demand Control Ventilation | If required by Section 6.4.3.9 (spaces >500 sf with >40 people/1,000 sf) | No | | No | | Yes | | |
| *Economizer High-Limit Shutoff (°F) | •Systems 1, 2, 9 & 10: N, A •Systems 3-8: as required by G3.1.2.6 & G3.1.2.7 by Climate Zone: • Not Required - 1a, 1b, 2a, 3a, 4a • 75°F - 1b, 2b, 3b, 3c, 4b, 4c, 5b, 5c, 6b, 7b, 8 • 70°F - 5a, 6a, 7a | Fixed Temp (Integrated) 75 | °F | Fixed Temp (Integrated) 75 | °F | Fixed Temp (Integrated) 75 | °F | |

Table 1.4 - Air-Side HVAC System Schedule

| Model Input Parameter | Helpful Notes | HVAC System / Group | | HVAC System / Group | | HVAC System / Group | | Totals |
|--|---|---------------------|----------|---------------------|----------|---------------------|----------|--------|
| | | Description | Units | Description | Units | Description | Units | |
| *Supply Air Temperature Reset | Systems 5-8: Supply air temperature reset of 5°F under minimum cooling load conditions per G3.1.3.12 (e.g. from 55 °F to 60 °F) | Warmest Zone | | Warmest Zone | | Warmest Zone | | |
| *Any individual systems with ≥5,000 cfm supply air and ≥70% outdoor air? | •Exhaust air energy recovery required for individual systems with ≥5,000 cfm supply air and ≥70% outdoor air per G3.1.2.10 unless any exceptions apply | None | | None | | None | | |
| *Exhaust Air Energy Recovery Effectiveness or G3.1.2.10 Exception Claimed | •50% energy recovery effectiveness •Bypass or control to permit economizer | | | | | | | |
| Supply Fan Power | •Sum of fan power for all supply, return, relief, and exhaust fans cannot exceed G3.1.2.9 system fan power allowance calculated using supply cfm | 1.53 | kW | 2.10 | kW | 2.41 | kW | |
| Return/Relief Fan Power | •Report exhaust fans not interlocked with HVAC operation (such as parking garage ventilation fans, or unconditioned electrical room exhaust fans), and exhaust fans not required in the calculations (such as fume hoods applying Exception 6.5.3.1.1, or kitchen hoods operating independently of the building HVAC system) in Table 1.4.4 | 0.00 | kW | 0.00 | kW | 0.00 | kW | |
| Exhaust Fan Power | | 0.00 | kW | 0.00 | kW | 0.00 | kW | |
| System Fan Power | | 1.53 | kW | 2.10 | kW | 2.41 | kW | 6.0 |
| Allowed Fan Power: | These values are calculated based on, system type, any pressure adjustments listed below, the total supply volume, and the ASHRAE 90.1 fan motor efficiency associated with the fan bhp. | 1.53 | kW | 2.10 | kW | 2.41 | kW | 6.0 |
| * Total Table 6.5.3.1.1B Pressure Drop Adjustments (A). | | 0.00 | bhp | 0.00 | bhp | 0.00 | bhp | |
| Pressure Drop Adjustments: (Systems 3 through 8) | •For each pressure adjustment allowed, enter the Baseline cfm through each device (CFM ₀) | cfm | in. w.c. | cfm | in. w.c. | cfm | in. w.c. | |
| * Fully ducted return and/or exhaust air systems | Adjustment = 0.5 in. w.c. | | | | | | | |
| * Return and/or exhaust airflow control devices | only where modulated to maintain relative negative or positive space pressure (e.g. lab, operating room) | | | | | | | |
| * Exhaust filters, scrubbers, or other exhaust treatment | Adjustment = Pressure drop of device calculated at fan system design condition | | | | | | | |
| * Particulate Filtration Credit: MERV 9 through 12 | Adjustment = 0.5 in. w.c. | | | | | | | |
| * Particulate Filtration Credit: MERV 13 through 15 | Adjustment = 0.9 in. w.c. | | | | | | | |
| * Particulate Filtration Credit: MERV 16 and greater and electronically enhanced filters | Adjustment = Pressure drop calculated at 2× clean filter pressure drop at fan system design condition | | | | | | | |
| * Carbon and other gas-phase air cleaners | Adjustment = Clean filter pressure drop at fan system design condition | | | | | | | |
| * Heat recovery device | •only if modeled in Baseline per G3.1.2.10 •Adjustment = Pressure drop of device at fan system design condition | | | | | | | |
| * Evaporative humidifier/cooler in series with another cooling coil | •only if modeled in Baseline • Adjustment = Clean filter pressure drop at fan system design condition | | | | | | | |
| * Sound Attenuation Section | Adjustment = 0.15 in. w.c. | | | | | | | |
| * Fume Hood Exhaust Exception | required if 6.5.3.1.1 Exception [c] is taken | | | | | | | |
| * Non-mechanical cooling fan volume | For system types #9 and #10, if present in the proposed design, increases the baseline fan power allowance by 0.054 Watts/cfm. | | cfm | | cfm | | cfm | |

***See Instructions above**

Table 1.4 - Air-Side HVAC System Schedule

Table 1.4.7B - Proposed Air-Side HVAC System Schedule

Instructions: Instructions: Enter all applicable input parameters for the Proposed air-side HVAC systems below. All systems included in the model should be entered. Each individual system may be entered separately, or multiple systems may be grouped together if all input parameters identified with an (*) are similar. The table is set up for two unique HVAC systems (or two groups of similar systems), and additional systems (or groups of similar systems) should be added as necessary using the Add a System button. An example of the expected level of detail has been provided for each input. Please refer to the Helpful Notes for information about Appendix G modeling protocol. For any information not applicable to the project, simply enter "N/A".

Table 1.4.7B - Proposed Air-Side HVAC System Schedule

| Model Input Parameter | Helpful Notes | HVAC System / Group | | HVAC System / Group | | HVAC System / Group | | Totals |
|---------------------------------------|---|-------------------------------|--------|-------------------------------|--------|-------------------------------|--------|--------|
| | | Description | Units | Description | Units | Description | Units | |
| *System Type | All inputs should be consistent with the Proposed energy model and the mechanical drawings and equipment schedules submitted in LEED Online | Packaged DX Single Zone | | Packaged DX Single Zone | | Packaged DX Single Zone | | |
| System Designation(s) | | Retail Mech. System | | Office Mech System | | Restaurant Mech Sys. | | |
| Number of Similar Systems | | 1 | | 1 | | 1 | | |
| Total Cooling Capacity | | 72 | kBtu/h | 72 | kBtu/h | 160 | kBtu/h | 304 |
| *Unitary Cooling Efficiency | Units should be consistent with the ASHRAE 90.1 minimum efficiency rating requirements for this system type | 12.0 EER | | 12.0 EER | | 11.4 EER | | |
| *Unitary Cooling Part-load Efficiency | Indicate the part-load efficiency. Also describe the method for modeling part-load curves if the energy simulation does not have default curves for this equipment type. Enter N/A if not applicable. | n/a | | n/a | | n/a | | |
| Total Heating Capacity | All inputs should be consistent with the Proposed energy model and the mechanical drawings and equipment schedules submitted in LEED Online | 92 | kBtu/h | 61 | kBtu/h | 148 | kBtu/h | 301 |
| *Unitary Heating Efficiency | List all relevant efficiencies (e.g. 3.2 COP at 47°F db/43°F wb, 2.0 COP at 17°F db/15°F wb outdoor air) | 81% AFUE | | 81% AFUE | | 82% AFUE | | |
| *Fan Control | e.g. Variable Speed Fans, 3-speed ECM fans with automated controls, constant speed, etc. | Variable Speed Drive | | Variable Speed Drive | | Variable Speed Drive | | |
| Supply Airflow | Inputs should be consistent with the mechanical drawings and equipment schedules submitted in LEED Online | 2,400 | cfm | 2,400 | cfm | 5,000 | cfm | 9,800 |
| Outdoor Airflow | Actual minimum outdoor airflow rates consistent with Mechanical Schedule | 320 | cfm | 288 | cfm | 750 | cfm | 1,358 |
| Demand Control Ventilation | Briefly describe how demand control ventilation was modeled | Yes | | No | | Yes | | |
| *Economizer Control | Describe the type of economizer control and the high limit shutoff. Also indicate if the economizer controls are for less than 100% of the design supply air. | Diff. Temp (Integrated) 75 | °F | Diff. Temp (Integrated) 75 | °F | Diff. Temp (Integrated) 75 | °F | |

Table 1.4 - Air-Side HVAC System Schedule

| Model Input Parameter | Helpful Notes | HVAC System / Group | | HVAC System / Group | | HVAC System / Group | | Totals |
|-------------------------------|---|---------------------|-------|---------------------|-------|---------------------|-------|--------|
| | | Description | Units | Description | Units | Description | Units | |
| *Supply Air Temperature Reset | e.g. - Supply air temperature reset from 55°F to 62°F based on worst case zone | Constant Temp | | Constant Temp | | Constant Temp | | |
| *Exhaust Air Energy Recovery | If the system includes energy recovery, describe the type of energy recovery and recovery effectiveness (example: enthalpy wheel - 75% effective). Otherwise, enter "N/A". | None | | None | | None | | |
| Supply Fan Power | *Report exhaust fans not interlocked with HVAC operation (such as parking garage ventilation fans, or unconditioned electrical room exhaust fans), and exhaust fans not required in the calculations (such as fume hoods applying Exception 6.5.3.1.1, or kitchen hoods operating independently of the building HVAC system) in Table 1.4.4 | 1.07 | kW | 1.01 | kW | 2.61 | kW | |
| Return/Relief Fan Power | | 0.00 | kW | 0.00 | kW | 0.00 | kW | |
| Exhaust Fan Power | | 0.00 | kW | 0.00 | kW | 0.00 | kW | |
| System Fan Power | | 1.07 | kW | 1.01 | kW | 2.61 | kW | 4.7 |
| Other (Describe) | | | | | | | | |
| Other (Describe) | | | | | | | | |
| Other (Describe) | | | | | | | | |
| Other (Describe) | | | | | | | | |
| Other (Describe) | | | | | | | | |
| Other (Describe) | | | | | | | | |
| Other (Describe) | | | | | | | | |
| Other (Describe) | | | | | | | | |
| Other (Describe) | | | | | | | | |
| Other (Describe) | | | | | | | | |
| Other (Describe) | | | | | | | | |
| Other (Describe) | | | | | | | | |
| Other (Describe) | | | | | | | | |
| Other (Describe) | | | | | | | | |

*See Instructions above

Table 1.4 - Air-Side HVAC System Schedule

Table 1.4.8 - Water-Side HVAC System Schedule

Instructions: Enter all applicable input parameters for the Baseline and Proposed water-side HVAC systems below. All systems included in the model should be entered. An example of the expected level of detail has been provided for each input. Please refer to the Helpful Notes for information about Appendix G modeling protocol. For any information not applicable to the project, simply enter "N/A". If taking credit for a campus or district plant efficiency using the DES v2 Option 2 Guidance, please include all relevant information regarding the District Plant equipment in the Proposed Case. For projects using the DES v2 Option 2 Guidance Option 1, or ASHRAE 90.1 Addendum ai for district energy systems, it is recommended that the Proposed Case inputs be completed first, and the description for many Baseline Case inputs will be auto-generated based on the proposed case inputs. Baseline Helpful notes relevant to DES v2 Option 1 and ASHRAE 90.1 Addendum ai are abbreviated as "DESv2#1" and "ai" respectively.

| Model Input Parameter | | Baseline Helpful Notes | Baseline Case | Units | Proposed Case | Units |
|-----------------------|--|---|------------------------|--------|------------------------|--------|
| Chilled Water | Number and Type of Chillers (and capacity per chiller if more than one type or size of chiller) | <ul style="list-style-type: none"> •≤300 tons building peak: 1 water-cooled screw chiller •300-600 tons building peak: 2 equally-sized water-cooled screw chillers •≥600 tons building peak: At least 2 water-cooled centrifugal chillers (800 tons max per chiller) | | | | |
| | Total Chiller Capacity | Auto-sized with 15% oversizing (unless oversized at the system coil) per G3.1.2.2 | 0 | tons | 0 | tons |
| | Chiller Efficiency - Full Load | Per Table 6.8.1C efficiencies | | kW/Ton | | kW/Ton |
| | Chiller Efficiency - Part Load | | | | | |
| | Chilled Water (CHW) Supply Temp | 44°F per G3.1.3.8 | 44 | °F | 44 | °F |
| | CHW ΔT | 12°F per G3.1.3.8 | | °F | | °F |
| | CHW Supply Temp Reset Parameters | 44°F at outdoor temps 80°F and above, 54°F at outdoor temps 60°F and below, and ramped linearly between 44°F and 54°F at outdoor temps between 80°F and 60°F per G3.1.3.9 | not a DOE-2 capability | | not a DOE-2 capability | |
| | CHW Loop Configuration | Primary/secondary per G3.1.3.10 | Primary Only | | Primary Only | |
| | Number of Primary CHW Pumps | 1 per chiller per G3.1.3.11 | 0 | # | 0 | # |
| | Primary CHW Pump Power | 22 W/gpm per G3.1.3.10 | | W/gpm | | W/gpm |
| | Primary CHW Pump Flow | Auto-sized with a capacity ratio of 1.0 based on CHW temperatures | | gpm | | gpm |
| | Primary CHW Pump Control | Constant Flow - each primary pump interlocked to operate with associated chiller - G3.1.3.10, G3.1.3.11 | Constant Flow | | Constant Flow | |
| | Number of Secondary CHW Pumps | 1 per G3.1.3.10 | | # | 1 | # |
| | Secondary CHW Pump Power | 22 W/gpm per G3.1.3.10 | | W/gpm | 0.00 | W/gpm |
| | Secondary CHW Pump Flow | Auto-sized with a capacity ratio of 1.0 based on CHW temperatures | | gpm | 0 | gpm |

| Model Input Parameter | | Baseline Helpful Notes | Baseline Case | Units | Proposed Case | Units |
|---------------------------------|--|---|---------------|--------|--------------------------|--------|
| | Secondary CHW Pump Control | <300 tons: riding the pump curve ≥300 tons: variable speed | | | One-Speed / 3 Way Valves | |
| | Water-Side Economizer | Not required | No | | No | |
| | Water-Side Energy Recovery | Not required | | | | |
| Cooling Tower & Condenser Water | Number of Cooling Towers / Fluid Coolers | 1 per G3.1.3.11 | 0 | # | 0 | # |
| | Cooling Tower Fan Power | Minimum 38.2 gpm/hp (maximum 0.0262 hp/gpm or 19.5 W/gpm) per Table 6.8.1G | | gpm/Hp | | gpm/Hp |
| | Cooling Tower Fan Control | Two-speed axial fans per G3.1.3.11 | | | | |
| | Condenser Water (CW) Leaving Temp | 85°F or 10°F approaching design wet-bulb temperature, whichever is lower per G3.1.3.11 | | °F | | °F |
| | CW ΔT | 10°F per G3.1.3.11 | | °F | | °F |
| | CW Loop Temp Reset Parameters | Maintain a 70°F leaving water temperature where weather permits, floating up to leaving water temperature at design conditions per G3.1.3.11 | | | | |
| | Number of CW Pumps | 1 per chiller per G3.1.3.11 | 0 | # | 0 | # |
| | CW Pump Power | 19 W/gpm per G3.1.3.11 | | W/gpm | | W/gpm |
| | CW Pump Flow | Auto-sized with a capacity ratio of 1.0 based on CW temperatures | | gpm | | gpm |
| | CW Pump Control | Riding the pump curve per G3.1.3.11 | | | | |
| Hot Water / Steam | Number and Type of Boilers | ≤15,000 sf: 1 natural draft hot water boiler >15,000 sf: 2 equally-sized natural draft hot water boilers staged as required by the load | | | | |
| | Total Boiler Capacity | Auto-sized with 25% oversizing (unless oversized at the system coil) per G3.1.2.2 | | | | |
| | Boiler Efficiency | Per Table 6.8.1F minimum efficiencies | | | | |
| | Hot Water or Steam (HHW) Supply Temp | 180°F per G3.1.3.3 | | °F | | °F |
| | HHW ΔT | 50°F per G3.1.3.3 | | °F | | °F |
| | HHW Temp Reset Parameters | 180°F at outdoor temps 20°F and below, 150°F at outdoor temps 50°F and above, and ramped linearly between 180°F and 150°F at outdoor temps between 20°F and 50°F per G3.1.3.4 | | | Primary Only | |
| | HHW Loop Configuration | Primary-only per G3.1.3.5 | | | 1 | |
| | Number of Primary HHW Pumps | One pump per Boiler | | # | 0 | # |
| | Primary HHW Pump Power | 19 W/gpm per G3.1.3.5 | | W/gpm | 0 | W/gpm |
| | Primary HHW Pump Flow | Auto-sized with a capacity ratio of 1.0 based on HHW temperatures | | gpm | One-Speed / 3 Way Valves | gpm |
| | Primary HHW Pump Control | <120,000 sf: riding the pump curve ≥120,000 sf: variable speed | | | | |